

Test Certificate

No. 8-7/97

according to DIN EN 1303:2005-04

We confirm, that
the manufacturer

KABA GmbH
A-3730 Eggenburg

meet the requirements
of DIN EN 1303

at the date of

28. January 2005
28. July 2005

for the product

Quattro S
Expert T

in the version

Double-, half- and knobcylinder

that complies with
the Classification.

Classification according to DIN EN 1303								
Position	1	2	3	4	5	6	7	8
	Category of use	Durability	Door mass	Fire resistance	Safety	Corrosion resistance and temperature	Key related Security	Attack resistance
Class	1	6	0	0	0	C	6	2
The classification in clause 6 shall be quoted in the accompanying documents relevant to the cylinder, on its labelling or packaging and / or by marking the product itself or by more than one of these methods.								

This certificate is based on the evaluation of test report No. 8-7/97 and 8-2/03 by PIV Velbert.

Velbert, the 1 August 2005

Hans-Jürgen Kirchhoff, Dipl.-Ing.
Head of Test Laboratory

This is a document page.
Partly publications or changes of content is forbidden.
Coloured copies must be identified as such ones.
Disregard means document forgery.